

प्रमाण पत्र

प्रमाणित किया जाता है कि **L.S.P. Public School** रामपुर कलां (खुटार-पुवायॉ रोड) जिला-शाहजहाँपुर में संचालित है जो कि **C.B.S.E. New Delhi** से सम्बद्ध है। विद्यालय में शुद्ध पेयजल एवं साफ -सफाई की समुचित व्यवस्था उपलब्ध है।

दिनांक- 15.06.2023

प्राथमिक स्वास्थ्य केन्द्र
खुटार-शाहजहाँपुर
शिक्षा अधीक्षक
सामुदायिक स्वास्थ्य केन्द्र
खुटार (शाहजहाँपुर)


Manager
L. S. P. Public School
Rampur Kalan, Shahjahanpur (U.P.)


PRINCIPAL
L. S. P. PUBLIC SCHOOL
Rampur Kalan, Shahjahanpur (U.P.)



AquaCare
ENVIRONMENTAL LABORATORY
(AN ISO 9001:2015 CERTIFIED LABORATORY)

TEST REPORT

Sample Code No : ACEL/05/080
Sample Receipt Date : 30.05.2023
Analysis Date : 30.05.2023 to 05.06.2023
Date of Report Issue : 05.06.2023
Customer Ref No / Date: Nil

Sample Description : Water
Sample Quantity : 1 litre
Sample Condition : Satisfactory
Sample Detail : Water Sample
Sample Type : **Drinking Water**

ISSUED TO:

Customer Name : **L.S.P Public School**
Address : **Rampur Kalan Khutar Road Shahjahanpur**

TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
SI No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Odour	-	Agreeable	Agreeable	IS:3025 (Part 05)-1983
2.	Taste	-	Agreeable	Agreeable	IS:3025 (Part 08)-1984
4.	Turbidity	NTU	0.1	1	IS:3025 (Part 10)-1984
5.	pH value	-	7.25	6.5-8.5	IS:3025 (Part 11)-1983
6.	Total Dissolved Solids	mg/l	137	500	IS:3025 (Part 16)-1984
7.	Total Hardness as CaCO ₃	mg/l	64	200	IS:3025 (Part 21)-2009
8.	Calcium as Ca ⁺⁺	mg/l	16	75	IS:3025 (Part 40)-1991
9.	Magnesium as Mg ⁺⁺	mg/l	4.8	30	IS:3025 (Part 46)-1994
10.	Total Alkalinity as CaCO ₃	mg/l	40	200	IS:3025 (Part 23)-1986
11.	Chloride as Cl ⁻	mg/l	38	250	IS:3025 (Part 32)-1988
12.	Free Residual Chlorine	mg/l	BDL(DL=0.2)	0.2	IS:3025 (Part 26)-2021
13.	Sulphate as SO ₄ ⁻	mg/l	BDL(DL=5.0)	200	IS:3025 (Part 24)-1986
14.	Fluoride as F ⁻	mg/l	BDL(DL=0.10)	1.0	IS:3025 (Part 60)-2008
15.	Total Iron as Fe ⁺	mg/l	BDL(DL=0.05)	1.0	IS:3025 (Part 53)-2003
16.	Nitrate as NO ₃ ⁻	mg/l	1.1	45	IS:3025 (Part 34)-1988
SI No	BACTERIOLOGICAL		RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Total Coliforms (MPN/100ml)		Not Detected	Not Detected	IS:1622 -1981
2.	Faecal Coliforms (MPN/100ml)		Not Detected	Not Detected	IS:1622 -1981
3.	<i>E. coli</i> in 100 ml of sample present/absent		Not Detected	Not Detected	IS:1622 -1981

BDL= Below Detection Limit. DL=Detection Limit.

Remarks: -

- 1) The Above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- 2) The results relate to item tested.



Page 1 of 1

LAB ADDRESS

C-348, 3rd Floor, Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077
Contact Details : +91 8219717330, 9736108733 Email : aquacare.envlab@gmail.com


Manager
L. S. P. Public School
Rampur Kalan, Shahjahanpur (U.P.)


PRINCIPAL
L. S. P. PUBLIC SCHOOL
Rampur Kalan, Shahjahanpur (U.P.)



AquaCare

ENVIRONMENTAL LABORATORY
(AN ISO 9001:2015 CERTIFIED LABORATORY)

TEST REPORT

Sample Code No : ACEL/05/079
Sample Receipt Date : 30.05.2023
Analysis Date : 30.05.2023 to 05.06.2023
Date of Report Issue : 05.06.2023
Customer Ref No / Date: Nil

Sample Description : Water
Sample Quantity : 1 litre
Sample Condition : Satisfactory
Sample Detail : Water Sample
Sample Type : Raw Water

ISSUED TO:

Customer Name : L.S.P Public School
Address : Rampur Kalan Khutar Road Shahjahanpur

TEST RESULTS


PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
SI No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Odour	-	Agreeable	Agreeable	IS:3025 (Part 05)-1983
2.	Taste	-	Agreeable	Agreeable	IS:3025 (Part 08)-1984
4.	Turbidity	NTU	0.3	1	IS:3025 (Part 10)-1984
5.	pH value	-	7.25	6.5-8.5	IS:3025 (Part 11)-1983
6.	Total Dissolved Solids	mg/l	134	500	IS:3025 (Part 16)-1984
7.	Total Hardness as CaCO ₃	mg/l	68	200	IS:3025 (Part 21)-2009
8.	Calcium as Ca ⁺⁺	mg/l	17.6	75	IS:3025 (Part 40)-1991
9.	Magnesium as Mg ⁺⁺	mg/l	5.8	30	IS:3025 (Part 46)-1994
10.	Total Alkalinity as CaCO ₃	mg/l	40	200	IS:3025 (Part 23)-1986
11.	Chloride as Cl ⁻	mg/l	38	250	IS:3025 (Part 32)-1988
12.	Free Residual Chlorine	mg/l	BDL(DL=0.2)	0.2	IS:3025 (Part 26)-2021
13.	Sulphate as SO ₄ ⁻	mg/l	6.1	200	IS:3025 (Part 24)-1986
14.	Fluoride as F ⁻	mg/l	BDL(DL=0.10)	1.0	IS:3025 (Part 60)-2008
15.	Total Iron as Fe	mg/l	BDL(DL=0.05)	1.0	IS:3025 (Part 53)-2003
16.	Nitrate as NO ₃ ⁻	mg/l	12	45	IS:3025 (Part 34)-1988
SI No	BACTERIOLOGICAL		RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Total Coliforms (MPN/100ml)		11	Not Detected	IS:1622-1981
2.	Faecal Coliforms (MPN/100ml)		Not Detected	Not Detected	IS:1622-1981
3.	E. coli in 100 ml of sample present/absent		Not Detected	Not Detected	IS:1622-1981

BDL= Below Detection Limit, DL=Detection Limit.

Remarks: -

- The Above water sample conforms to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- The results relate to item tested.

Page 1 of 1



LAB ADDRESS

C-348, 3rd Floor, Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077
Contact Details : +91 8219717330, 9736108733 Email : aquacare.envlab@gmail.com

Manager
L. S. P. Public School
Rampur Kalan, Shahjahanpur (U.P.)

PRINCIPAL
L. S. P. PUBLIC SCHOOL
Rampur Kalan, Shahjahanpur (U.P.)